

Comm Hill 2 Phase II Perimeter Sample Results
 Week of September 21st through September 25th, 2020

| Sampling Date | P1 | | | P2 | | | P3 | | | P4 | | | P5 | | |
|--------------------------|-------------------------|------------------------|----------------------------|-------------------------|------------------------|----------------------------|-------------------------|------------------------|----------------------------|-------------------------|------------------------|----------------------------|-------------------------|------------------------|----------------------------|
| | Chrysotile ¹ | Amphibole ² | Structures/cc ³ | Chrysotile ¹ | Amphibole ² | Structures/cc ³ | Chrysotile ¹ | Amphibole ² | Structures/cc ³ | Chrysotile ¹ | Amphibole ² | Structures/cc ³ | Chrysotile ¹ | Amphibole ² | Structures/cc ³ |
| 9/21/2020 | ND | ND | <0.0010 | 1 | ND | 0.0010 | 1 | ND | 0.0010 | 10 | ND | 0.0099 | 6 | ND | 0.0060 |
| 9/22/2020 | ND | ND | <0.0010 | 1 | 1 | 0.0019 | 1 | ND | 0.0010 | 1 | ND | 0.0010 | 2 | ND | 0.0019 |
| 9/23/2020 | 1 | ND | 0.0009 | 3 | ND | 0.0028 | 6 | 1 | 0.0066 | 4 | ND | 0.0038 | ND | ND | <0.0009 |
| 9/24/2020 | ND | ND | <0.0010 | ND | ND | <0.0010 | 2 | ND | 0.0019 | 10 | ND | 0.0093 | ND | ND | <0.0009 |
| 9/25/2020 | ND | ND | <0.0010 | ND | ND | <0.0010 | 4 | ND | 0.0039 | 1 | ND | 0.0010 | ND | 1 | 0.0010 |
| BAAQMD Guidelines | | | | | | | | | | | | <0.016 Structures/cc | | | |

| Sampling Date | P6 | | | P7 | | | P8 | | | |
|--------------------------|-------------------------|------------------------|----------------------------|-------------------------|------------------------|----------------------------|-------------------------|------------------------|----------------------------|----------------------|
| | Chrysotile ¹ | Amphibole ² | Structures/cc ³ | Chrysotile ¹ | Amphibole ² | Structures/cc ³ | Chrysotile ¹ | Amphibole ² | Structures/cc ³ | |
| 9/21/2020 | 1 | ND | 0.0010 | 5 | ND | 0.0049 | 6 | 1 | 0.0069 | |
| 9/22/2020 | 7 | 1 | 0.0076 | 3 | 1 | 0.0038 | 8 | ND | 0.0088 | |
| 9/23/2020 | ND | ND | <0.0009 | 2 | ND | 0.0019 | 5 | 1 | 0.0056 | |
| 9/24/2020 | 3 | 1 | 0.0038 | 15 | ND | 0.0143 | 13 | ND | 0.0122 | |
| 9/25/2020 | ND | ND | <0.0010 | ND | ND | <0.0010 | 3 | ND | 0.0029 | |
| BAAQMD Guidelines | | | | | | | | | | <0.016 Structures/cc |

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Indicates that no asbestos structures were detected in the grid openings scanned

BAAQMD Guidelines Trigger Level for increased dust control measures