

**Comm Hill 2 Phase II Perimeter Sample Results**  
 Week of January 18th through January 24th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
1/18/2021	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	13	ND	0.0125	ND	ND	<0.0010
1/19/2021	ND	ND	<0.0010	9	ND	0.0086	10	ND	0.0095	5	ND	0.0048	1	ND	0.0010
1/20/2021	ND	ND	<0.0010	1	4	0.0048	17	ND	0.0163	4	1	0.0048	3	ND	0.0029
1/21/2021	ND	ND	<0.0009	1	3	0.0039	9	ND	0.0087	8	2	0.0096	ND	ND	<0.0010
1/22/2021	ND	ND	<0.0009	ND	ND	<0.0009	ND	1	0.0009	ND	1	0.0009	1	ND	0.0009
1/23/2021	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010
<b>BAAQMD Guidelines</b> <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9c			P10c		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
1/18/2021	2	ND	0.0019	10	ND	0.0098	9	ND	0.0084	16	ND	0.0151	8	ND	0.0076
1/19/2021	7	1	0.0076	8	2	0.0097	20	1	0.0200	76	ND	0.1204	14	2	0.0152
1/20/2021	ND	ND	<0.0010	1	ND	0.0010	2	ND	0.0019	4	ND	0.0038	8	1	0.0086
1/21/2021	ND	ND	<0.0010	2	ND	0.0020	13	1	0.0135	7	ND	0.0067	2	1	0.0029
1/22/2021	1	ND	0.0009	ND	ND	<0.0009	ND	ND	<0.0009	1	ND	0.0009	3	ND	0.0028
1/23/2021	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	1	ND	0.0010	ND	1	0.0010
<b>BAAQMD Guidelines</b> <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures