

Comm Hill 2 Phase II Perimeter Sample Results

Week of June 22nd through June 26th, 2020

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc
6/22/2020	ND	ND	<0.0010	1	ND	0.0009	1	ND	0.0009	11	ND	0.0105	37	1	0.0354
6/23/2020	ND	ND	<0.0009	2	1	0.0029	4	1	0.0048	11	2	0.0124	5	3	0.0075
6/24/2020	ND	ND	<0.0010	3	ND	0.0028	3	ND	0.0028	3	ND	0.0029	1	ND	0.0009
6/25/2020	1	ND	0.0009	2	ND	0.0019	3	ND	0.0028	2	ND	0.0019	2	ND	0.0019
6/26/2020	1	ND	0.0009	ND	ND	<0.0009	ND	ND	<0.0009	1	ND	0.0010	7	ND	0.0066
BAAQMD Guidelines										<0.016 Structures/cc					

Sampling Date	P6			P7			P8		
	Chrysotile	Amphibole	Structures /cc	Chrysotile	Amphibole	Structures /cc ³	Chrysotile	Amphibole ²	Structures /cc ³
6/22/2020	7	ND	0.0068	3	ND	0.0029	5	1	0.0057
6/23/2020	1	ND	0.0010	1	1	0.0019	9	1	0.0096
6/24/2020	3	ND	0.0028	ND	ND	<0.0009	2	ND	0.0019
6/25/2020	8	ND	0.0074	4	ND	0.0038	2	ND	0.0019
6/26/2020	11	ND	0.0104	6	ND	0.0056	5	ND	0.0047
BAAQMD Guidelines									
<0.016 Structures/cc									

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Indicates that no asbestos structures were detected in the grid openings scanned

BAAQMD Guidelines Trigger Level for increased dust control measures