

**Comm Hill 2 Phase II Perimeter Sample Results**  
**Week of March 7th through March 11th, 2022**

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
3/7/2022	Removed from monitoring network			ND	1	0.0010	Intermittent monitoring			Removed from monitoring network			ND	ND	<0.0010
3/8/2022				2	1	0.0031							ND	ND	<0.0010
3/9/2022				2	ND	0.0021							ND	ND	<0.0010
3/10/2022				ND	ND	<0.0010							ND	ND	<0.0010
3/11/2022				1	ND	0.0010							ND	ND	<0.0010
<b>BAAQMD Guidelines</b>			<b>&lt;0.016 Structures/cc</b>												

Sampling Date	P6			P7			P8			P9d			P10e		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
3/7/2022	ND	ND	<0.0010	ND	ND	<0.0010	1	ND	0.0010	1	ND	0.0010	4	ND	0.0039
3/8/2022	1	1	0.0021	ND	1	0.0010	1	ND	0.0010	4	ND	0.0041	1	ND	0.0010
3/9/2022	2	ND	0.0021	2	1	0.0031	6	1	0.0072	6	2	0.0083	12	ND	0.0124
3/10/2022	ND	ND	<0.0010	1	ND	0.0010	4	ND	0.0041	3	ND	0.0031	5	ND	0.0052
3/11/2022	ND	ND	<0.0010	2	ND	0.0021	15	ND	0.0155	4	1	0.0052	5	1	0.0062
<b>BAAQMD Guidelines</b>			<b>&lt;0.016 Structures/cc</b>												

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured

1/20/2022 Sampling Location moved from P10d to P10e