

Comm Hill 2 Phase II Perimeter Sample Results
 Week of February 15th through February 19th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
2/15/2021	NM														
2/16/2021	ND	ND	<0.0009	ND	ND	<0.0009	2	ND	0.0019	ND	ND	<0.0009	ND	ND	<0.0009
2/17/2021	1	ND	0.0010	3	ND	0.0029	6	ND	0.0058	1	ND	0.0010	ND	ND	<0.0010
2/18/2021	ND	1	0.0010	2	1	0.0029	6	ND	0.0058	3	1	0.0038	2	ND	0.0019
2/19/2021	ND	ND	<0.0010	2	1	0.0029	2	ND	0.0019	3	ND	0.0029	ND	ND	<0.0010
BAAQMD Guidelines <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9c			P10c		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
2/15/2021															
2/16/2021	1	ND	0.0009	3	1	0.0038	3	ND	0.0028	3	ND	0.0029	4	ND	0.0038
2/17/2021	1	ND	0.0010	6	ND	0.0059	3	ND	0.0029	3	ND	0.0030	1	ND	0.0010
2/18/2021	ND	ND	<0.0010	3	ND	0.0029	5	ND	0.0048	11	ND	0.0115	ND	ND	<0.0010
2/19/2021	2	ND	0.0019	9	ND	0.0087	15	ND	0.0145	6	2	0.0077	5	1	0.0058
BAAQMD Guidelines <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures