

## Comm Hill 2 Phase II Perimeter Sample Results

Week of February 22nd through February 26th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
2/22/2021	1	ND	0.0010	1	ND	0.0010	1	1	0.0019	3	ND	0.0029	3	ND	0.0029
2/23/2021	ND	1	0.0010	1	ND	0.0010	18	1	0.0188	10	1	0.0109	1	ND	0.0010
2/24/2021	1	ND	0.0010	2	ND	0.0019	6	1	0.0067	1	ND	0.0010	ND	ND	<0.0010
2/25/2021	ND	ND	<0.0010	3	ND	0.0029	4	1	0.0048	3	ND	0.0029	3	ND	0.0029
2/26/2021	1	ND	0.0010	1	ND	0.0009	18	ND	0.0170	1	ND	0.0010	ND	ND	<0.0010
<b>BAAQMD Guidelines</b>			<b>&lt;0.016 Structures/cc</b>												

Sampling Date	P6			P7			P8			P9c			P10c		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
2/22/2021	ND	ND	<0.0010	4	ND	0.0038	3	ND	0.0029	1	ND	0.0009	7	ND	0.0069
2/23/2021	ND	ND	<0.0010	7	ND	0.0070	7	1	0.0080	10	1	0.0109	12	ND	0.0116
2/24/2021	4	ND	0.0038	1	1	0.0019	1	ND	0.0010	2	ND	0.0019	6	ND	0.0058
2/25/2021	2	ND	0.0019	5	ND	0.0048	5	ND	0.0048	12	ND	0.0119	11	ND	0.0107
2/26/2021	1	ND	0.0010	14	1	0.0141	7	ND	0.0067	5	ND	0.0048	1	ND	0.0010
<b>BAAQMD Guidelines</b>			<b>&lt;0.016 Structures/cc</b>												

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures