

## Comm Hill 2 Phase II Perimeter Sample Results

Week of January 25th through January 29th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
1/25/2021	ND	ND	<0.0009	ND	ND	<0.0009	ND	ND	<0.0009	4	ND	0.0039	ND	ND	<0.0009
1/26/2021	ND	ND	<0.0009	ND	ND	<0.0009	3	1	0.0037	ND	ND	<0.0009	1	ND	0.0009
1/27/2021	50	ND	0.1765	3	ND	0.0029	1	ND	0.0009	2	ND	0.0019	ND	ND	<0.0010
1/28/2021	ND	ND	<0.0010	1	ND	0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010
1/29/2021	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010
<b>BAAQMD Guidelines</b> <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9c			P10c		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
1/25/2021	ND	ND	<0.0009	ND	ND	<0.0009	1	ND	0.0010	1	ND	0.0010	ND	ND	<0.0010
1/26/2021	ND	ND	<0.0009	ND	ND	<0.0009	2	ND	0.0018	6	ND	0.0054	ND	1	0
1/27/2021	ND	ND	<0.0010	1	ND	0.0010	2	ND	0.0019	ND	ND	<0.0010	2	ND	0.0019
1/28/2021	ND	ND	<0.0010	1	ND	0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010
1/29/2021	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010
<b>BAAQMD Guidelines</b> <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures