

Comm Hill 2 Phase II Perimeter Sample Results
 Week of October 4th through October 8th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
10/4/2021	2	ND	0.0020	2	ND	0.0020	8	ND	0.0079	2	3	0.0049	1	6	0.0069
10/5/2021	ND	1	0.0010	4	ND	0.0040	3	1	0.0090	1	1	0.0020	2	2	0.0040
10/6/2021	ND	ND	<0.0010	12	1	0.0131	2	ND	0.0020	4	ND	0.0040	ND	ND	<0.0010
10/7/2021	ND	ND	<0.0010	2	1	0.0030	2	ND	0.0020	3	ND	0.0030	ND	ND	<0.0010
10/8/2021	2	ND	0.0020	6	ND	0.0060	ND	ND	<0.0010	1	ND	0.0010	ND	1	0.0010
BAAQMD Guidelines			<0.016 Structures/cc												

Sampling Date	P6			P7			P8			P9d			P10d		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
10/4/2021	3	ND	0.0030	2	ND	0.0020	1	5	0.0059	3	2	0.0049	3	ND	0.0030
10/5/2021	ND	1	0.0010	1	ND	0.0010	2	ND	0.0020	2	ND	0.0020	3	ND	0.0030
10/6/2021	3	ND	0.0030	2	ND	0.0020	3	ND	0.0030	7	ND	0.0071	1	ND	0.0010
10/7/2021	3	1	0.0041	2	2	0.0041	4	ND	0.0041	1	ND	0.0010	2	ND	0.0020
10/8/2021	11	ND	0.0111	1	ND	0.0010	1	ND	0.0010	1	1	0.0020	5	ND	0.0050
BAAQMD Guidelines			<0.016 Structures/cc												

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured