

Comm Hill 2 Phase II Perimeter Sample Results

Week of December 13th through December 17th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
12/13/2021															
12/14/2021															
12/15/2021	ND	ND	<0.0010	1	ND	0.0010	5	ND	0.0050	ND	ND	<0.0010	ND	ND	<0.0010
12/16/2021															
12/17/2021															
BAAQMD Guidelines										<0.016 Structures/cc					

Sampling Date	P6			P7			P8			P9d			P10d		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
12/13/2021															
12/14/2021															
12/15/2021	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	2	ND	0.0020	1	2	0.0031
12/16/2021															
12/17/2021															
BAAQMD Guidelines										<0.016 Structures/cc					

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured