

**Comm Hill 2 Phase II Perimeter Sample Results**  
**Week of February 1st through February 5th, 2021**

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
2/1/2021	ND	ND	<0.0009	ND	ND	<0.0009	ND	ND	<0.0009	1	ND	0.0010	ND	ND	<0.0009
2/2/2021	1	ND	0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	1	ND	0.0010
2/3/2021	ND	ND	<0.0009	1	ND	0.0010	2	ND	0.0018	3	ND	0.0028	ND	ND	<0.0009
2/4/2021	ND	ND	<0.0010	2	ND	0.0020	19	2	0.0255	6	ND	0.0059	ND	1	0.0010
2/5/2021	ND	ND	<0.0010	2	ND	0.0020	2	1	0.0030	1	ND	0.0010	ND	ND	<0.0010
<b>BAAQMD Guidelines</b> <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9c			P10c		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
2/1/2021	ND	ND	<0.0009	ND	ND	<0.0009	3	ND	0.0028	10	ND	0.0095	1	ND	0.0010
2/2/2021	ND	ND	<0.0010	ND	ND	<0.0010	1	ND	0.0010	2	ND	0.0019	6	ND	0.0057
2/3/2021	ND	ND	<0.0010	7	ND	0.0063	6	ND	0.0055	2	1	0.0028	8	ND	0.0074
2/4/2021	1	ND	0	4	ND	0.0039	10	ND	0.0098	4	ND	0.0039	4	1	0.0049
2/5/2021	ND	ND	<0.0010	3	ND	0.0030	7	ND	0.0070	ND	ND	<0.0010	79	ND	0.0729
<b>BAAQMD Guidelines</b> <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures