

Comm Hill 2 Phase II Perimeter Sample Results
 Week of March 1st through March 5th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
3/1/2021	2	ND	0.0019	ND	ND	<0.0010	2	ND	0.0019	1	1	0.0019	3	ND	0.0029
3/2/2021	1	ND	0.0010	ND	1	0.0010	3	ND	0.0029	6	1	0.0067	2	1	0.0029
3/3/2021	ND	ND	<0.0010	3	1	0.0039	7	ND	0.0067	ND	ND	<0.0010	3	1	0.0038
3/4/2021	ND	ND	<0.0010	2	1	0.0029	ND	ND	<0.0010	ND	ND	<0.0010	1	1	0.0019
3/5/2021	ND	ND	<0.0010	6	1	0.0068	11	ND	0.0108	ND	ND	<0.0010	ND	ND	<0.0010
BAAQMD Guidelines			<0.016 Structures/cc												

Sampling Date	P6			P7			P8			P9c			P10c		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
3/1/2021	1	ND	0.0009	ND	ND	<0.0010	2	ND	0.0019	10	ND	0.0095	4	ND	0.0038
3/2/2021	2	ND	0.0020	2	ND	0.0020	ND	ND	0.0010	2	1	0.0029	3	ND	0.0029
3/3/2021	1	ND	0.0010	1	ND	0.0010	5	ND	0.0048	1	ND	0.0010	7	ND	0.0067
3/4/2021	ND	1	0.0010	1	ND	0.0010	4	ND	0.0039	7	ND	0.0067	7	ND	0.0067
3/5/2021	ND	ND	<0.0010	ND	1	0.0010	ND	2	0.0019	5	ND	0.0049	ND	ND	<0.0010
BAAQMD Guidelines			<0.016 Structures/cc												

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures