

## Comm Hill 2 Phase II Perimeter Sample Results

Week of March 29th through April 2nd, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
3/29/2021	1	ND	0.0010	6	1	0.0067	9	ND	0.0086	3	ND	0.0029	2	1	0.0029
3/30/2021	1	ND	0.0010	5	ND	0.0048	ND	ND	<0.0010	7	1	0.0077	ND	ND	<0.0010
3/31/2021	1	ND	0.0010	3	1	0.0038	4	1	0.0048	3	2	0.0049	11	1	0.0115
4/1/2021	ND	ND	<0.0010	3	1	0.0039	ND	1	0.0010	5	ND	0.0048	3	ND	0.0029
4/2/2021	ND	ND	<0.0010	8	4	0.0115	1	5	0.0058	6	2	0.0077	3	ND	0.0029
BAAQMD Guidelines <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9c			P10c		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
3/29/2021	ND	ND	<0.0010	3	ND	0.0029	2	ND	0.0019	14	ND	0.0134	2	1	0.0029
3/30/2021	2	ND	0.0019	9	ND	0.0086	7	ND	0.0067	12	ND	0.0113	9	ND	0.0086
3/31/2021	4	1	0.0048	2	1	0.0029	9	ND	0.0087	21	1	0.0539	8	ND	0.0077
4/1/2021	3	1	0.0039	4	2	0.0058	2	1	0.0029	6	1	0.0067	4	ND	0.0038
4/2/2021	2	1	0.0029	3	ND	0.0029	3	1	0.0038	3	1	0.0040	1	ND	0.0010
BAAQMD Guidelines <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures