

## Comm Hill 2 Phase II Perimeter Sample Results

Week of April 19th through April 23rd, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
4/19/2021	ND	ND	<0.0010	2	ND	0.0019	ND	ND	<0.0010	3	2	0.0049	ND	ND	<0.0010
4/20/2021	ND	ND	<0.0010	2	2	0.0039	2	ND	0.0019	3	ND	0.0029	3	1	0.0039
4/21/2021	1	ND	0.0010	7	1	0.0076	2	2	0.0039	ND	ND	<0.0010	ND	1	0.0010
4/22/2021	ND	ND	<0.0010	1	ND	0.0010	3	ND	0.0029	1	ND	0.0010	ND	ND	<0.0010
4/23/2021	ND	ND	<0.0010	2	ND	0.0019	ND	ND	<0.0009	ND	ND	<0.0010	1	ND	0.0010
<b>BAAQMD Guidelines</b>			<b>&lt;0.016 Structures/cc</b>												

Sampling Date	P6			P7			P8			P9d			P10d		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
4/19/2021	ND	ND	<0.0010	2	ND	0.0019	3	2	0.0048	9	ND	0.0087	4	ND	0.0039
4/20/2021	1	ND	0.0010	3	ND	0.0029	2	ND	0.0019	2	1	0.0029	2	ND	0.0019
4/21/2021	ND	ND	<0.0010	3	ND	0.0029	1	ND	0.0010	9	ND	0.0086	4	ND	0.0038
4/22/2021	1	ND	0.0010	4	1	0.0048	9	ND	0.0086	4	ND	0.0038	7	ND	0.0066
4/23/2021	ND	ND	<0.0010	1	ND	0.0010	5	1	0.0058	5	ND	0.0048	1	ND	0.0010
<b>BAAQMD Guidelines</b>			<b>&lt;0.016 Structures/cc</b>												

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures