

**Comm Hill 2 Phase II Perimeter Sample Results**  
 Week of April 5th through April 9th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
4/5/2021	ND	ND	<0.0010	2	ND	0.0019	1	ND	0.0010	2	ND	0.0019	ND	ND	<0.0010
4/6/2021	ND	ND	<0.0009	10	ND	0.0093	3	1	0.0038	ND	ND	<0.0009	ND	ND	<0.0009
4/7/2021	ND	ND	<0.0010	3	ND	0.0029	1	ND	0.0010	ND	2	0.0019	ND	ND	<0.0010
4/8/2021	ND	1	0.0010	2	ND	0.0019	4	ND	0.0038	2	2	0.0038	2	ND	0.0019
4/9/2021	ND	ND	<0.0010	9	1	0.0098	ND	1	0.0010	6	2	0.0078	1	ND	0.0010
<b>BAAQMD Guidelines</b> <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9d			P10d		
	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>	Chrysotile <sup>1</sup>	Amphibole <sup>2</sup>	Structures/cc <sup>3</sup>
4/5/2021	7	ND	0.0068	4	ND	0.0039	2	ND	0.0019	13	ND	0.0126	3	ND	0.0029
4/6/2021	1	2	0.0028	ND	1	0.0009	4	ND	0.0038	10	1	0.0105	3	ND	0.0028
4/7/2021	ND	ND	<0.0010	3	1	0.0039	2	ND	0.0019	7	ND	0.0067	12	ND	0.0115
4/8/2021	2	ND	0.0019	5	ND	0.0047	3	ND	0.0028	3	ND	0.0029	1	ND	0.0010
4/9/2021	ND	1	0.0010	5	1	0.0059	3	ND	0.0029	4	2	0.0058	3	ND	0.0029
<b>BAAQMD Guidelines</b> <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND

BAAQMD Guidelines Trigger Level for increased dust control measures