

Comm Hill 2 Phase II Perimeter Sample Results
 Week of May 16th through May 20th, 2022

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
5/16/2022				2	ND	0.0020							ND	ND	<0.0010
5/17/2022				3	ND	0.0031							2	ND	0.0021
5/18/2022				ND	ND	<0.0010							1	1	0.0021
5/19/2022				1	ND	0.0010							ND	ND	<0.0010
5/20/2022				ND	ND	<0.0010							ND	ND	<0.0010
BAAQMD Guidelines										<0.016 Structures/cc					

Sampling Date	P6			P7			P8			P9d			P10e		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
5/16/2022	ND	ND	<0.0010	1	ND	0.0010	2	ND	0.0020	4	ND	0.0040	5	ND	0.0049
5/17/2022	ND	ND	<0.0010	2	ND	0.0021	9	ND	0.0092	3	ND	0.0031	13	ND	0.0134
5/18/2022	ND	ND	<0.0010	1	ND	0.0010	3	ND	0.0031	5	ND	0.0052	7	ND	0.0072
5/19/2022	1	ND	0.0010	2	ND	0.0021	4	ND	0.0041	5	ND	0.0052	12	ND	0.0124
5/20/2022	ND	ND	<0.0010	7	ND	0.0072	9	1	0.0103	6	ND	0.0062	2	ND	0.0021
BAAQMD Guidelines										<0.016 Structures/cc					

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured

1/20/2022 Sampling Location moved from P10d to P10e