

Comm Hill 2 Phase II Perimeter Sample Results

Week of July 19th through July 23rd, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
7/19/2021	ND	ND	<0.0010	2	ND	0.0019	4	ND	0.0038	1	ND	0.0010	ND	ND	<0.0010
7/20/2021	3	ND	0.0029	ND	ND	<0.0010	3	ND	0.0029	ND	ND	<0.0010	ND	ND	<0.0010
7/21/2021	ND	ND	<0.0009	2	1	0.0028	ND	ND	<0.0009	4	ND	0.0037	ND	ND	<0.0009
7/22/2021	5	ND	0.0049	1	ND	0.0010	2	1	0.0029	3	3	0.0056	ND	ND	<0.0010
7/23/2021	ND	ND	<0.0010	3	1	0.0039	ND	ND	<0.0010	2	ND	0.0020	ND	ND	<0.0010
BAAQMD Guidelines <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9d			P10d		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
7/19/2021	2	ND	0.0019	3	1	0.0038	3	ND	0.0029	4	1	0.0048	ND	ND	<0.0009
7/20/2021	1	1	0.0019	ND	ND	<0.0010	1	ND	0.0010	ND	ND	<0.0010	2	ND	0.0020
7/21/2021	7	1	0.0075	ND	ND	<0.0009	10	ND	0.0093	4	ND	0.0037	1	ND	0.0009
7/22/2021	2	ND	0.0020	1	ND	0.0010	2	ND	0.0020	2	ND	0.0020	1	ND	0.0010
7/23/2021	1	ND	0.0010	2	ND	0.0020	ND	ND	<0.0010	1	1	0.0019	2	1	0.0029
BAAQMD Guidelines <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured