

Comm Hill 2 Phase II Perimeter Sample Results
 Week of July 12th through July 16th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
7/12/2021	1	ND	0.0009	ND	1	0.0009	ND	ND	<0.0009	2	ND	0.0019	1	ND	0.0009
7/13/2021	2	1	0.0029	2	ND	0.0019	ND	ND	<0.0010	4	ND	0.0038	ND	ND	<0.0010
7/14/2021	1	1	0.0020	ND	ND	<0.0010	ND	ND	<0.0010	2	ND	0.0020	2	ND	0.0020
7/15/2021	ND	1	0.0010	3	ND	0.0029	5	ND	0.0048	13	2	0.0143	ND	1	0.0010
7/16/2021	ND	ND	<0.0010	4	1	0.0049	3	ND	0.0029	3	ND	0.0029	ND	ND	<0.0010
BAAQMD Guidelines <0.016 Structures/cc															

Sampling Date	P6			P7			P8			P9d			P10d		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
7/12/2021	3	1	0.0037	ND	ND	<0.0009	3	ND	0.0028	ND	ND	<0.0009	3	ND	0.0028
7/13/2021	ND	1	0.0010	1	ND	0.0010	3	ND	0.0029	3	ND	0.0029	4	ND	0.0038
7/14/2021	10	2	0.0117	2	ND	0.0020	1	ND	0.0010	3	ND	0.0029	1	ND	0.0010
7/15/2021	ND	ND	<0.0010	1	ND	0.0010	7	ND	0.0067	2	ND	0.0019	9	1	0.0095
7/16/2021	ND	ND	<0.0010	1	1	0.0019	3	1	0.0039	3	ND	0.0029	1	ND	0.0010
BAAQMD Guidelines <0.016 Structures/cc															

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured