

Comm Hill 2 Phase II Perimeter Sample Results

Week of August 16th through August 20th, 2021

Sampling Date	P1			P2			P3			P4			P5		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
8/16/2021	ND	ND	<0.0010	6	ND	0.0061	1	ND	0.0010	1	ND	0.0010	ND	ND	<0.0010
8/17/2021	ND	ND	<0.0010	10	ND	0.0101	13	ND	0.0133	1	ND	0.0010	2	ND	0.0020
8/18/2021	3	ND	0.0030	4	ND	0.0040	8	ND	0.0081	1	1	0.0020	12	ND	0.0122
8/19/2021	1	ND	0.0010	4	ND	0.0041	2	ND	0.0020	1	ND	0.0010	1	ND	0.0010
8/20/2021	ND	1	0.0010	4	ND	0.0041	1	ND	0.0010	ND	ND	<0.0010	ND	ND	<0.0010
BAAQMD Guidelines										<0.016 Structures/cc					

Sampling Date	P6			P7			P8			P9d			P10d		
	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³	Chrysotile ¹	Amphibole ²	Structures/cc ³
8/16/2021	2	ND	0.0021	ND	ND	<0.0010	2	ND	0.0018	1	ND	0.0010	ND	ND	<0.0010
8/17/2021	3	ND	0.0030	2	1	0.0030	14	ND	0.0142	2	ND	0.0020	3	ND	0.0030
8/18/2021	2	ND	0.0020	1	1	0.0020	1	1	0.0020	5	ND	0.0051	1	1	0.0020
8/19/2021	1	ND	0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010	ND	ND	<0.0010
8/20/2021	1	ND	0.0010	1	ND	0.0010	1	ND	0.0010	ND	1	0.0010	ND	ND	<0.0010
BAAQMD Guidelines										<0.016 Structures/cc					

1 - Chrysotile Asbestos

2 - Amphibole Asbestos - Including regulated and non-regulated amphibole asbestos

3 - Structures/CC - Calculated Asbestos Structure Concentration per CC Air

ND Not Detect

BAAQMD Guidelines Trigger Level for increased dust control measures

NM Not Measured